

Building Renewal Grant Application

Initial Submission Date:

Application ID: 62

Resubmittal Date:

Please provide as much of the requested information as possible. SFB staff will assist in developing required information that is not currently available.

District Name: Yarnell Elementary District

Superintendent: Fred Garnett

Contact Person: Fred Garnett

Contact Phone Number: 928-427-3347

Contact Email: fgarnett001@gmail.com

School Site: Yarnell Elementary School

Buildings: 1002 Replacement school

Description of Problem

Please include a detailed description of the issues, as well as a description of and a copy of any professional studies, citations or reports from government entities, recommended solutions, and any cost information or estimates. If additional space is needed, please attach.

Issues:

- 1) The water pump system that filters the drinking water, and provides the correct pressure for the fire hydrants has an inconsistent water pressure problem. The main bearing in the water pump that provides pressure to the school and is regulated by the back flow system failed this month. The repair was approximately \$1,000.00. The alarm system indicates there is a problem with the pump/pump pressure daily.
- 2) The alarm system alarms daily indicating a smoke detector is defective, and the smoke detector shows green on its test panel. Every morning the alarm has tripped with varying problems. We check out the problems and there doesn't seem to be anything wrong. The fire alarm system is not interfaced with the local fire department. Actually the building could burn and no-one would know until someone reported the fire.
- 3) The Airconditioning ventilation system does not meet the needs of the building in the boys bathroom, office bathroom, girls bathroom. The food service storage room is not ventilated or airconditioned. The airconditioners constantly leak into the classrooms. The custodians repair the leaks sometimes weakly. The Air conditioner drainage pipe leaks in xx units, seeps through the ceiling and stains the carpet

Project Category: HVAC

Are any of the above-described issues in buildings or part of buildings that are leased to another entity, including a district sponsored charter school? N

Available Funding

Building Renewal Grant Application

Current unencumbered building renewal fund balance (Fund 690):	\$0.00
Amount of Local funds planned for this project	\$0.00

Please outline any associated insurance coverage.

In order to keep taxes consistent, the district did not budget for these repairs, and we were told no monies were available? We reduced our operating costs by 5.7% In a rural school this is a significant dollar amount.

Liaison: Breuer

gbreuer@azsfb.gov

602-542-6139

Superintendent Printed Name

Superintendent Signature

Date